

RC-0093-AC-2019

The Reconstruction of County Line Road

Russell Township and the Village of Hunting Valley, Geauga and Cuyahoga County


CLARIFICATION #1

Friday, April 26, 2019

BID SPECIFICATION CLARIFICATION

1. **Proposal Item 54 – 832 - Stormwater Pollution Prevention Plan.** This item shall include preparation, submittal and approval of a swp3 plan utilizing the provided TSEC items of work. Inspection by a certified individual is required per SS832.11
2. **Proposal Item 81 – 253 - Pavement Repair, As Per Plan.** This item applies to pavement repair over storm sewer trenches in the resurfacing portion of the project
3. **Proposal Item 84 – 304 - Aggregate Base (Drives), As Per Plan.** The plan notes on sheet 15 of 297 calls for 304 aggregate for backfill of pipe trenches where conduit is not being replaced. A quantity has been included in the plans at the drives. Plan quantity for this item may be adjusted during construction where necessary to prepare the pipe trench prior to paving.
4. **Proposal Item 109 – Special - Water Work Misc.: City of Cleveland Water Department Charges.** The Cleveland Department of Water (CWD) has issued a formal charge letter for necessary charges to review, inspect and approve the waterline improvements. The total fee is \$9,283.50. This value shall be used for the respective bid item for these charges.
5. Existing waterline is C.L. 52 ductile iron
6. A temporary waterline bypass will not be required. Pressure test and chlorination will be required prior to re-connection.
7. Utility pole relocation will be by the respective utility companies. The contractor will not be responsible for the cost to relocate. Temporary support may be necessary to facilitate some grading and drainage work until all poles are moved. This should be considered incidental to the respective scope item. Pole relocation may be performed concurrently with the project.
8. This clarification does not change the plan quantities, project cost or schedule.

This concludes the scope of Clarification #1 for the project.



Shane E. Hajjar, PE

Deputy Engineer

Geauga County Engineer's Office